



ميديل ايست لخدمات الفحص Middle East Testing Services



STANDARD METHOD FOR THE TESTING AND EVALUATION OF VOLATILE ORGANIC CHEMICAL (VOC) EMISSIONS FROM INDOOR SOURCES USING ENVIRONMENTAL CHAMBERS VERSION 1.2-CALIFORNIA DEPARTMENT OF PUBLIC HEALTH (CDPH)

(Emission testing method for California Specification 01350)

Laboratory Report

1. Introduction

Middle East Testing Laboratory L.L.C (METS) were contacted by Uzin Utz Middle East Trading LLC and requested to perform 14 days (336 hrs.) emission test as per CDPH Method Version 1.2.

Client : Uzin Utz Middle East Trading LLC
Al Hudaiba Mall, 2nd Floor Al Mina Street, Al Hudaiba P.O. Box 126732,
Dubai, United Arab Emirates
Report No : MR-130626-299
Reporting Date : 01/07/2026
Tested by : SH
Date of Analysis : 13/06/2026-28/06/2026
Issue No : 01 (Re-Issue Date: NA)

2. Sample Information

Sample Description : UZIN KE 16 NEW

3. Brief Evaluation of the Results:

MS-130626-299	TVOC and Individual VOC's of Concern		Formaldehyde	
	Criterion	Compliance	Criterion	Compliance
	TVOC: <0.5 mg/m ³	PASS	≤9.0µg/m ³	PASS
	Individual VOC: < Limit	PASS		

Details furnished in following pages

Prepared by

Team Head
Material Science Division (MSD)
Employee Code: METS AJ EC 220

Verified by

Supervisor
Fire & Material Science Division
Employee Code: METS AJ EC 110

